



NOTE: PERMANENT BLOW-OFFS DO NOT REQUIRE A JOINT OF D.I.P. OR A VALVE.
 ALSO ALL BLOW-OFFS NEED TO BE PLACED AT PROPERTY LINES.

PROPER AMOUNT OF RESTRAINED PIPE UPSTREAM OF VALVE MAY BE USED
 IN LIEU OF THRUST COLLAR.

2" BLOW-OFF FOR
 10" WATER MAINS
 AND SMALLER



CITY OF COCOA
 Brevard County, Florida
 UTILITIES DEPARTMENT
 ENGINEERING DIVISION

BLOW-OFF DETAIL 1

DRAWN BY: J. WILLIAMS	SCALE: NOT TO SCALE
CHECKED BY: P. DAVIS	DATE: MARCH 2020
DESIGN BY:	SHEET: 1 OF 3
ACAD NAME: BLOW OFF DETAIL 1	