



NOTES:

1. ALTHREAD ROD WILL NOT BE PERMITTED.
 2. 90° BENDS MAY BE INSTALLED IN LIEU OF 45° BENDS IF APPROVED BY FIRELINE ENGINEER & CITY OF COCOA.
 3. FIRE DEPARTMENT CONNECTIONS (FDC) WILL NOT BE PERMITTED ON ABOVE GROUND PIPING.
 4. ASSEMBLY TO BE PAINTED RUST-OLEUM 9400 SYSTEM (RED) BY THE CITY, PAID FOR BY THE CONTRACTOR.
 5. ALL ABOVE GROUND BOLTS AND NUTS TO BE 18-8 TYPE 304 STAINLESS STEEL.
 6. CITY OWNS AND MAINTAINS TO BOTTOM FITTING ON DOWNSTREAM SIDE.
 7. FOUR TO SIX BOLLARDS MAY BE REQUIRED, SPACED 18" FROM CENTERLINE.
 8. A FIRELINE CONTRACTOR SHALL BE REQUIRED FROM THE FIRELINE POINT OF SERVICE.
- © REFER TO THRUST BLOCK NOTES & DETAILS.



CITY OF COCOA
 Brevard County, Florida
 UTILITIES DEPARTMENT
 ENGINEERING DIVISION

DOUBLE CHECK DETECTOR ASSEMBLY

DRAWN BY: J. WILLIAMS	SCALE: NOT TO SCALE
CHECKED BY: P. DAVIS	DATE: MARCH 2020
DESIGN BY:	SHEET: 1 OF 1
ACAD NAME: DOUBLE CHECK DETECTOR ASSEMBLY	