



LINESTOP SPECIFICATIONS:
SEE SECTION 1.2.4.5

SUPPORT BLOCK
SEE DETAIL SHEET 78

COLLAR BLOCK
SEE DETAIL SHEETS 88 & 89

FORM & POUR SUPPORT BLOCK ON UNDISTURBED OR COMPACTED EARTH
AFTER LINE STOP FITTING IS INSTALLED & BEFORE LINE STOP MACHINE IS
MOUNTED FOR 16"-20", A= LENGTH OF FITTING PLUS 6"

NOTES:
4"-8" LINE STOP REQUIRES 1" BLEEDER TAP
10" AND LARGER REQUIRES 2" BLEEDER TAP
SEE "SERVICE CONNECTION" SPECIFICATIONS
SEE APPENDIX "A" FOR APPROVED MATERIAL

PIPE SIZE (INCHES)			
	A	B	C
4	18"	6"	6"
6	18"	6"	6"
8	24"	6"	6"
10	24"	8"	8"
12	30"	8"	8"
16	SEE NOTE	12"	12"
20	SEE NOTE	18"	18"

CONCRETE ANCHOR SUPPORT



CITY OF COCOA
Brevard County, Florida
UTILITIES DEPARTMENT
ENGINEERING DIVISION

LINE STOP DETAIL FOR TIE IN OR CAPPING EXISTING WATER MAIN

DRAWN BY: J. WILLIAMS	SCALE: NOT TO SCALE
CHECKED BY: P. DAVIS	DATE: MARCH 2020
DESIGN BY:	SHEET: 1 OF 1
ACAD NAME: LINE STOP DETAIL FOR TIE IN OR CAPPING EXISTING WATER MAIN	