



NOTES:

1. ALL UNDERGROUND PIPING IS TO BE DUCTILE IRON WITH RESTRAINED MECHANICAL JOINTS, POLYETHYLENE WRAPPED
2. PIPING SIZES TO BE DETERMINED BY THE ENGINEER OF RECORD AND APPROVED BY COCOA UTILITIES
3. ALL WORK IS TO CONFORM TO CITY OF COCOA STANDARDS.



CITY OF COCOA
 Brevard County, Florida
 UTILITIES DEPARTMENT
 ENGINEERING DIVISION

MASTER METER ASSEMBLY PLAN

DRAWN BY: J. WILLIAMS	SCALE: NOT TO SCALE
CHECKED BY: P. DAVIS	DATE: MARCH 2020
DESIGN BY:	SHEET: 1 OF 3
ACAD NAME: MASTERMETERASSEMBLY1	