



NOTES:

1. ALTHREAD ROD WILL NOT BE PERMITTED.
  2. FIRE DEPARTMENT CONNECTIONS (FDC) WILL NOT BE PERMITTED ON ABOVE GROUND PIPING.
  3. ASSEMBLY TO BE PAINTED RUST-O-THANE RED NO. 9405-1611
  4. ALL ABOVE GROUND BOLTS AND NUTS TO BE 18-8 TYPE 304 STAINLESS STEEL.
  5. CITY OWNS AND MAINTAINS TO BOTTOM FITTING ON DOWNSTREAM SIDE.
  6. FOUR TO SIX BOLLARDS MAY BE REQUIRED, SPACED 18" FROM CENTERLINE.
  7. A FIRELINE CONTRACTOR SHALL BE REQUIRED FROM THE FIRELINE POINT OF SERVICE.
- © REFER TO "THRUST BLOCK" NOTES & DETAILS.



**CITY OF COCOA**  
Brevard County, Florida  
UTILITIES DEPARTMENT  
ENGINEERING DIVISION

## "N" PATTERN DOUBLE CHECK DETECTOR ASSEMBLY

DRAWN BY: J. WILLIAMS	SCALE: NOT TO SCALE
CHECKED BY: P. DAVIS	DATE: MARCH 2020
DESIGN BY:	SHEET: 1 OF 1
ACAD NAME: N PATTERN DOUBLE CHECK DETECTOR ASSEMBLY	