

RESTRAINED PIPE TABLE
 WATER AND RECLAIMED WATER MAINS

MINIMUM LENGTH (FT) TO BE RESTRAINED ON EACH SIDE OF FITTING(S)								
TYPE	PIPE SIZE							
	4"	6"	8"	10"	12"	16"	20"	24"
90° BEND	21	29	38	45	53	66	79	91
45° BEND	9	12	16	19	22	45	33	38
22-1/2° BEND	5	6	8	9	11	14	16	19
11-1/4° BEND	3	3	4	5	6	7	8	9
PLUG, BRANCH OF TEE, VALVE	58	82	107	128	151	193	234	273

NOTES:

1. FITTINGS SHALL BE RESTRAINED JOINTS.
2. INSTALL FULL LENGTH JOINTS WITH TOTAL LENGTH EQUAL TO OR GREATER THAN SHOWN IN THE TABLE.
3. WHERE TWO OR MORE FITTINGS ARE TOGETHER, USE FITTING WHICH YIELDS GREATEST LENGTH OF RESTRAINED PIPE.
4. ALL LINE VALVES AND THROUGH RUN OF TEES SHALL BE RESTRAINED.
5. LENGTHS SHOWN IN THE TABLE HAVE BEEN CALCULATED IN ACCORDANCE WITH THE PROCEDURE OUTLINED IN "THRUST RESTRAINT DESIGN FOR DUCTILE IRON PIPE" AS PUBLISHED BY DIPRA, WITH THE FOLLOWING ASSUMPTIONS:

WORKING PRESSURE: 150 PSI
 SOIL DESIGNATION: SM (SAND SILT)
 LAYING CONDITIONS: 3

6. TABLE IS FOR PVC AND WRAPPED DUCTILE IRON.

