

SCHEDULE OF DIMENSIONS AND MATERIALS						
PIPE SIZE (INCHES)	DIMENSIONS (FT.)				TIE RODS REQ'D	
	A	B	C	D	DIA. (in.)	NO.
4	2.0	2.0	1.0	2.0	3/4	2
6	2.0	2.0	1.0	4.0	3/4	2
8	3.0	3.0	1.0	5.0	3/4	2
10	4.0	3.0	1.0	8.0	3/4	4
12	5.0	3.0	1.0	10.0	3/4	4
16	*	*	*	*	*	*
20	*	*	*	*	*	*
24	*	*	*	*	*	*

NOTE: THRUST COLLAR AREAS TO BE COMPUTED ON BASIS OF 2000 LBS/SF SOIL RESTRAINT BEARING. SOIL DENSITY ASSUMED 120 PCF. SOIL COHESION 20°.

NOTES:

1. ADDITIONAL REINFORCEMENTS SHALL BE AS SPECIFIED BY THE ENGINEER.
2. MINIMUM COMPRESSIVE STRENGTH FOR CONCRETE SHALL BE 3000 PSI.
3. BEDDING, BACKFILL AND COMPACTION SHALL BE AS SPECIFIED ELSEWHERE IN THE STANDARD DRAWINGS.
4. ALL FORM BOARDS SHALL BE REMOVED PRIOR TO BACKFILL.
5. NO ALLOWANCE SHALL BE MADE FOR FRICTION BETWEEN THE PIPE WALL AND THE THRUST COLLAR.
6. DESIGN PRESSURE: 150 PSI.
7. TIE RODS TO BE 3/4" SS 18-8 TYPE 304.

* TO BE DESIGNED BY ENGINEER OF RECORD.



CITY OF COCOA
Brevard County, Florida
UTILITIES DEPARTMENT
ENGINEERING DIVISION

THRUST COLLAR WATER AND RECLAIMED

DRAWN BY: J. WILLIAMS	SCALE: NOT TO SCALE
CHECKED BY: P. DAVIS	DATE: MARCH 2020
DESIGN BY:	SHEET: 2 OF 2
ACAD NAME: THRUST COLLAR WATER AND RECLAIMED 2 OF 2	